

**DECLARATION OF PERFORMANCE**  
**DoP No. 0893304700\_00\_M\_ENDLESS COLLAR**

1. Unique identification code of the product-type:

**Fire protection EC endless collar**

1a. Valid for Würth item numbers:

**08933047\***

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

**ETA – 13/0791**  
**Batch number: see delivery note**

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

**Pipe sealing for use in flexible and solid walls and solid floors**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

**Adolf Würth GmbH & Co. KG**  
**Reinhold-Würth-Strasse 12-17**  
**DE 74653 Künzelsau**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**Not relevant**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

**Not relevant**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

**the notified body MPA Braunschweig, No. 0761, has performed the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production on a regular basis according System 1.**

On the basis of: OIB Österreichisches Institut für Bautechnik, Vienna/Austria , **ETA – 13/0791, ETAG 026 part 2**

The notified body 0761 – CPD performed:

and following issued: **Certificate of conformity, 0761 – CPD - 0401**

9. Declared Performance:

<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonized technical specification</b>
Fire resistance as a pipe sealing for combustible or non-combustible non-insulated or insulated pipes in flexible wall -, rigid wall - or rigid floor constructions by means of the fire protection collar type EC Endless Collar with a maximum dimension of 160 mm.	≤ EI 240 U / C or ≤ EI 120 U / U	ETA-13/0791
Reaction to fire of the intumescent inlay ROKU® Strip	E	
Reaction to fire of the metal band	A1	
Durability and serviceability	use category type Y <sub>1</sub>	
Release of dangerous substances	none	
Air permeability	NPD	
Water permeability	NPD	
Mechanical resistance and stability	NPD	
Resistance to impact/movement	NPD	
Adhesion	NPD	
Airborne sound insulation	NPD	
Thermal resistance	NPD	
Water vapor permeability	NPD	

For more details please see ETA-13/0791	
---	--

Where pursuant to article 37 or 38 in the specific technical documentation has been used, the requirements with which the product complies:

**Not relevant**

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Marcel Strobel  
(Head of Product Management)  
Künzelsau, 03/07/2014



Dr.-Ing. Siegfried Beichter  
(Head of Quality, Authorized Signatory)